

ACCESSIBILITY PLAN

APPENDIX B: Bridlington School - Accessibility Plan

	Area of School	Issues arising	Proposed Resolution
Accessibility for wheelchair users - School plans marked to show ramp access, floor level access & disabled toilets.	Astro Centre / Reception	None	N/A
	Sports Hall	None	N/A
	Netball Courts	The yellow painted lines on the stairs to the netball courts are faded from use.	Lines to be re-painted.
	English Block	No accessible toilet in the staff or girls' toilets (no current need for this provision – to be reviewed as necessary).	Fittings have been made to one of the boys toilets (handle & pull down bar) so this can be used by boys with mobility issues. The nearest accessible toilet is in the Performing Arts / Maths block.
		A path has been resurfaced leading to the block which is an improvement, but there is a noticeable difference in height where it meets the path outside the block.	Requested this be filled to remove the risk of a wheelchair catching.
		The path around the block is quite narrow for wheelchair use.	Site team to review.
		The yellow painted lines on the stairs to the English block are faded from use.	Lines to be re-painted.
	Performing Arts	None	N/A
	Main Building – ground floor		
	Glass Corridor	There is a noticeable gap between the edge of the courtyard and the doorframes, making wheelchair access difficult.	Site team to repair.
	Fire exit from main stage & exit into the courtyard from Repro	The yellow painted lines on the stairs to the fire exit are faded.	Lines to be repainted.



ACCESSIBILITY PLAN

Main Building first floor (IT Rooms & Support Services)	Access to the nearest disabled toilet from support services is in Performing Arts, which is some distance away. The yellow painted lines on the stairs between IT1 & IT2 are faded from use.	Could consider adding a disabled toilet into the sixth form boys & girls toilets if necessary. Lines to be repainted.
Maths & Humanities	None	N/A
ADT block	No disabled toilet	Nearest disabled toilet is on the admin corridor in the main block.
	The yellow painted lines on the stairs to the main entrance (opp. Science) are faded).	Lines to be repainted.
Science & Languages	The yellow painted lines on the stairs to all entrances are faded from use.	Lines to be repainted.
Pavilion (POD)	None	N/A
Gym	No disabled toilet.	Nearest disabled toilet is at the Pavilion.
	Main entrance is not suitable for wheelchair.	Use entrance at the side of the gym which is at floor level.
	The yellow painted lines on the stairs to all entrances are faded from use.	Lines to be repainted.
	The yellow painted lines on the stairs to	Lines to be repainted.
	all the memorial garden are faded from use.	



ACCESSIBILITY PLAN

APPENDIX B: Bridlington School - Accessibility Plan continued ...

Markings for changes in height for visually impaired students	Astro Centre	None	N/A
	Sports Hall	None	N/A
	English Block	Markings on external steps	In place
	Performing Arts	None	Stairs have light vinyl with dark edge
	Main Building – IT	Markings on internal stairs up to IT rooms	In place
	Main Building – Support Services	None	Stairs have dark carpet with white edge.
	Maths & Humanities	None	Stairs have light vinyl tread with black edge
	Science & Languages	Stairs near to S1	Stairs have light vinyl tread with black edge
		Stairs to S7	Stairs are painted with yellow edge
		Stairs near S4	Stairs have light vinyl tread & dark edge
		Stairs to rear of MFL	Stairs are painted with yellow edge
	Pavilion (POD)	Markings on external steps	In place
	Gym	Markings on external steps	In place
	Harland House	Markings on external steps	In place

Date of audit: 16th September 2019

Mark Parker-Randall

Special Educational Needs & Disability Coordinator.

Signed Chair of Governors